

WELL DRILLERS REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 6821

1. OWNER ELMER PECETTI ADDRESS AT WELL LOCATION 11550 Thomas Creek Road
 MAILING ADDRESS 2250 Foothill Road Reno, NV 89511 Reno, NV

2. LOCATION SE 1/4 SE 1/4 Sec. 13 T. 18 N. N/S R. 19 E Washoe County
 PERMIT NO. 40-075-06 SW Reno

Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other Air/Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	1	1
Smaller gravels & sandwith brown clay		1	7	6
Boulder		7	9	2
Cemented boulder & gravels with brown sandy clay		9	48	39
Soft zone (NO WATER)		48	49	1
Cemented boulder & gravels with brown sandy clay		49	81	32
Hard granite boulder		81	97	16
Soft zone	x	97	98	1
Cemented boulder & gravels		98	111	13
Soft zone	x	111	113	2
Soft cemented boulders & gravels		113	149	36
Soft zone	x	149	151	2
Cemented boulder & gravels		151	165	14
Soft zone	x	165	169	4
Soft cemented boulder & gravels		169	179	10
Soft zone	x	179	181	2
Cemented boulders & gravels		181	187	6
Boulder		187	190	3

Date started 2-12-86, 19____
 Date completed 2-20-86, 19____

8. WELL CONSTRUCTION
 Diameter hole 10 x 6 inches Total depth 190 feet
 Casing record 190
 Weight per foot _____ Thickness .188

Diameter	From	To
<u>6 5/8</u> inches	<u>0</u> feet	<u>190</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type cement
 Depth of seal 51 feet
 Gravel packed: Yes No
 Gravel packed from 51 feet to 190 feet

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 2 1/2 x 6 around

From	feet to	feet
<u>100</u>	<u>120</u>	feet
<u>130</u>	<u>150</u>	feet
<u>160</u>	<u>180</u>	feet
_____	_____	feet
_____	_____	feet

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL
 Static water level 73 feet below land surface
 Flow 50 G.P.M. P.S.I.
 Water temperature cold °F. Quality clear

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling of Nevada, inc.
 Contractor
 Address P.O. Box 12370, Reno, NV 89510
 Contractor

Nevada contractor's license number 22549
 Nevada contractor's drillers number 908
 Nevada driller's license number 923
 Actual Driller

Signed [Signature] Contractor
 Date February 24, 1986

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours