

WELL DRILLERS REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 6720

OWNER Ron and Paula Kennedy ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 16110 Mt. Rose Hwy. 16110 Mt. Rose Hwy
Reno, Nv 89511
 2. LOCATION NW $\frac{1}{4}$ NE $\frac{1}{4}$ Sec 34 T. 18 N/S R. 19 E Washoe County
 PERMIT NO. 045-061-13 _____
 Issued by Water Resources Parcel No. Subdivision Name

| | | |
|---|--|---|
| 3. TYPE OF WORK | 4. PROPOSED USE | 5. TYPE WELL |
| New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/> | Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/> | Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/> |
| Deepen <input type="checkbox"/> Other <input type="checkbox"/> | Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/> | Other <input type="checkbox"/> Air <input type="checkbox"/> |

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|---|--------------|------|-----|------------|
| Loose dirt with some rock | | 0 | 21 | 21 |
| D.G. | | 21 | 25 | 4 |
| Hard Granite boulder | | 25 | 29 | 4 |
| D.G. Mixed with blue green and black with some red & white rock fragments | | 29 | 458 | 429 |
| There is a short 3' blank at the bottom of the perforated pipe for development. | | | | |
| T.D. 460 | | | | |

8.10"-55' WELL CONSTRUCTION

Diameter hole 8 inches Total depth 440 feet
 Casing record 6 5/8 - .156
 Weight per foot 10.58 Thickness .156

| Diameter | From | To |
|---------------------|----------------|-----------------|
| <u>6 5/8</u> inches | <u>+2</u> feet | <u>440</u> feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |

Surface seal: Yes No Type grout
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 440 feet

Perforations:
 Type perforation factory
 Size perforation 3/32 X 3
 From 417 feet to 437 feet
 From _____ feet to _____ feet

9. WATER LEVEL

Static water level 190 feet below land surface
 Flow 15 G.P.M. _____ P.S.I.
 Water temperature cool ° F. Quality good-slightly-irony

Date started 12/9/85, 19_____
 Date completed 12/11/85, 19_____

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|-------------------------------------|--------|-----------|------------------|
| Blew with air to clean and develop. | | | |
| _____ | _____ | _____ | _____ |
| _____ | _____ | _____ | _____ |

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling and Well Service, Inc.
 Contractor
 Address 2255 Glendale Ave. Sparks, Nv 89431
 Contractor
 Nevada contractor's license number 15291
 Nevada contractor's drillers number 1132
 Nevada driller's license number 1132
 Actual Driller
 Signed Roger M. Thrall Contractor
 Date 12/16/85

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours