

**WELL DRILLERS REPORT**

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 5827

1. OWNER JOH KEY ADDRESS AT WELL LOCATION \_\_\_\_\_  
MAILING ADDRESS P.O. Box 818 1435 Monte Vista  
Reno, NV 89504 7 18N 20 89511  
2. LOCATION SW 1/4 NE 1/4 Sec. 7 T. 18N N/S R. 20 E. Washoe County  
PERMIT NO. 47-084-20 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. TYPE OF WORK  
New Well  Recondition   
Deepen  Other   
4. PROPOSED USE  
Domestic  Irrigation  Test   
Municipal  Industrial  Stock   
5. TYPE WELL  
Cable  Rotary   
Other  air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	1/2	1/2
Boulder, sand, gravels with brown clay		1/2	30	29 1/2
Lose sands & gravels with brown clay streaks		30	92	62
Reddish brown volcanic rock		92	111	19
Soft zone [NO WATER]		111	112	1
Reddish brown volcanic rock		112	117	5
Soft zone [NO WATER]		117	120	3
Reddish brown volcanic rock		120	141	21
Soft zone	x	141	143	2
Reddish brown volcanic rock		143	159	16
Soft zone	x	159	162	3
Reddish brown volcanic rock		162	169	7

8. WELL CONSTRUCTION  
Diameter hole 10 x 6 inches Total depth 169 169 feet  
Casing record \_\_\_\_\_  
Weight per foot \_\_\_\_\_ Thickness .156  
Diameter From To  
6 5/8 inches 0 feet 120 feet  
5" liner inches 108 feet 169 feet  
\_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
\_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
\_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
Surface seal: Yes  No  Type cement 51 feet  
Depth of seal \_\_\_\_\_ feet  
Gravel packed: Yes  No   
Gravel packed from 51 feet to 169 feet  
Perforations:  
Type perforation factory sawed slot  
Size perforation 3/32 x 2" x 6 around  
From 100 feet to 120 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From 5" - 127 feet to 169 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 6-26-85, 19\_\_\_\_\_  
Date completed 7-1-85, 19\_\_\_\_\_  
7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL  
Static water level 40+ 23 feet below land surface  
Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature \_\_\_\_\_ °F. Quality clear

10. DRILLERS CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Wayne Drilling of Nevada, Inc.  
Contractor  
Address P.O. Box 12370, Reno, NV 89510  
Contractor  
Nevada contractor's license number 22549  
Nevada contractor's drillers number 908  
Nevada driller's license number 923  
Actual Driller

BAILER TEST  
G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

Signed Joseph P. Helman  
Contractor  
Date July 8, 1985