WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

26086
OFFICE USE ONLY
Log No. 26086
Permit No. 45235
Basin 6-87 Truckee Mead.

NOTICE OF INTENT NO. 6381

1. OWNER GERALD KIRKPATRICK
MAILING ADDRESS 301 ALAMO DRIVE
VACAVILLE, CALIFORNIA 95688

ADDRESS AT WELL LOCATION
SOUTH VIRGINIA STREET
PARCEL # 22-270-25

2. LOCATION SW ¼ ne ¼ Sec. 17 T. 18 (N)/S R. 20 E M.D.B. WASHOE County
PERMIT NO. 45235 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☒ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
clay & gravel		0	20	20
gravel		20	40	20
clay & gravel		40	51	11
sand & gravel		51	70	19
gravel w/some clay		70	85	15
gravel w/40% clay		85	100	15
clean sand		100	109	9
sand & gravel w/30% clay		109	116	7
clean gravel w/sand	XX	116	123	7
gravel w/40% clay	XX	123	140	17
sand & gravel w/clay	XX	140	152	12
broken rock w/clay	XX	152	160	8
gravel w/some clay	XX	160	180	20

Date started January 23, 19 86
Date completed January 25, 19 86

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
air lift	30		

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12-1/4 inches Total depth 180 feet
Casing record 8-5/8 inch O.D. x .188 wall
Weight per foot 16.94 Thickness

Diameter	From	To
8-5/8 inches	+1 feet	180 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement grout
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 180 feet
3/8 inch minus well rock
Perforations:
Type perforation Milled
Size perforation 3" x 1/8"
From 140 feet to 180 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 3 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature cold ° F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CHARLES SARGENT IRRIGATION, INC. (Contractor)
Address 9955 NO. VIRGINIA STREET RENO, NV 89506 (Contractor)
Nevada contractor's license number 21246
Nevada contractor's drillers number 1392
Nevada driller's license number 1413 (Actual Driller)
Signed [signature] (Contractor)
Date FEBRUARY 4, 1986

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434