WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Possibly Sec. 29
Duxbury, M.D.
14403 South Virginia

OFFICE USE ONLY
Log No. 26090
Permit No.
Basin Truckee Meadows #87

PRINT OR TYPE ONLY — Please complete this form in its entirety

NOTICE OF INTENT NO. 5950

OWNER Dr. Duxbury
MAILING ADDRESS 1 Booth St. Reno
ADDRESS AT WELL LOCATION White Cr. Rd. Reno

2. LOCATION ¼ ¼ Sec. 19 T. 18 N/S R. 20 E. Washoe County
PERMIT NO. (Issued by Water Resources) — Parcel No. 45-170-25 — Subdivision Name

3. TYPE OF WORK: New Well ☑ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☑ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☑ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	3	3
gravel & clay		3	18	15
large rocks & clay		18	106	88
Volcanic rock (grey)		106	134	28
red Volc. Rock		134	145	11
Lt grey Volc.		145	160	15
fractured Volc.	x	160	170	10
Multi colored Volc. rock		170	207	37
grey Volc.	x	207	224	17
reddish Brown Volc. rock	x	224	258	34
grey Volc. Rock		258	260	2

Date started 1-6, 1986
Date completed 1-12, 1986

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION

Diameter hole 18 inches Total depth 260 feet
Casing record
Weight per foot 9 Thickness .156

Diameter	From	To
6 5/8 O.D. inches	0 feet	260 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type sand & cement grout
Depth of seal 72 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 72 feet to 260 feet

Perforations:
Type perforation factory mill slot
Size perforation 3/32 x 2½"
From ..... feet to ..... feet
From ..... feet to ..... feet
From 210 feet to 260 feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL

Static water level approx. 100 feet below land surface
approx. 12 G.P.M. ..... P.S.I.
Water temperature 86 °F. Quality unknown

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Paul Williams & Sons (Contractor)
Address 22 So. Pattison, Sparks 89431 (Contractor)
Nevada contractor's license number ~~959~~ 14483
Nevada contractor's drillers number 957
Nevada driller's license number 957
Signed Paul E. Williams Jr. (Actual Driller)
Contractor
Date 1-13-86

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 26090
Permit No.
Basin TRUCKEE MEADOWS #87

DUXBURY, M.D. 14403 SOUTH VIRGINIA

WELL DRILLERS REPORT

PRINT OR TYPE ONLY — Please complete this form in its entirety

NOTICE OF INTENT NO. 5950

1. OWNER Dr. Duxbury
MAILING ADDRESS 1 Booth St. Reno
ADDRESS AT WELL LOCATION White Cr. Rd. Reno

2. LOCATION ¼ ¼ Sec. 19 T. 18 N/S R. 20 E. Washoe County
PERMIT NO. (Issued by Water Resources) Parcel No. 45-170-25 Subdivision Name THIS PARCEL IN SECTION 29 SEE ORIGINAL LOG IN SEC. 19

3. TYPE OF WORK: New Well ☑ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☑ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☑ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	3	3
gravel & clay		3	18	15
large rocks & clay		18	106	88
Volcanic rock (grey)		106	134	28
red Volc. Rock		134	145	11
Sandy grey Volc.		145	160	15
fractured Volc.	x	160	170	10
Multi colored Volc. rock		170	207	37
grey Volc.	x	207	224	17
reddish Brown Volc. rock	x	224	258	34
grey Volc. Rock		258	260	2

Date started 1-8, 1986
Date completed 1-12, 1986

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 18 inches Total depth 260 feet
Casing record
Weight per foot 9 Thickness .156

Diameter	From	To
6 5/8 O.D. inches	0 feet	260 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type sand & cement grout
Depth of seal 72 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 72 feet to 260 feet

Perforations:
Type perforation factory mill slot
Size perforation 3/32 x 2½"
From ..... feet to ..... feet
From ..... feet to ..... feet
From 210 feet to 260 feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level approx. 100 feet below land surface
approx. 12 G.P.M. ..... P.S.I.
Water temperature 86 °F. Quality fresh

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Paul Williams & Sons (Contractor)
Address 22 So. Pattison, Sparks 89431 (Contractor)
Nevada contractor's license number ~~959~~ 14483
Nevada contractor's drillers number 957
Nevada driller's license number 957
Signed Paul E. Williams Jr. (Actual Driller / Contractor)
Date 1-13-86

(Rev. 6-81) USE ADDITIONAL SHEETS IF NECESSARY O-627 CR434