WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLERS REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 26150
Permit No. 71173
Basin IR McDowell

NOTICE OF INTENT NO. 5293

1. OWNER Unitarian Universalist Fellowship of Reno
MAILING ADDRESS 780 Del Monte Lane
ADDRESS AT WELL LOCATION 780 Del Monte Lane

2. LOCATION NE ¼ ¼ Sec. 36 T 17 N/S R. 19 E Washoe County
PERMIT NO. 24604 7172 Issued by Water Resources (Washoe Co. Health)
Parcel No.
Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| sd & gravel | | 0 | 4 | 4 |
| yellow clay | | 4 | 40 | 36 |
| sd + gravel | | 40 | 60 | 20 |
| clay | | 60 | 82 | 22 |
| sd + clay | | 82 | 98 | 16 |
| sd + gravel | | 98 | 160 | 62 |

Date started 5-20, 1986
Date completed 5-21, 1986

7. WELL TEST DATA N/A

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | | | |

BAILER TEST N/A
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 11 inches Total depth 160 feet
Casing record 0-160
Weight per foot ..... Thickness .156

| Diameter | From | To |
|---|---|---|
| 6 5/8 inches | 0 feet | 160 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation slotted
Size perforation 1/8"
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 6' feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... °F. Quality cold

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Woytek Drilling (Contractor)
Address 4662 Maynard Sparks, Nv. (Contractor)
Nevada contractor's license number 12757
Nevada contractor's drillers number
Nevada driller's license number 1374 (Actual Driller)
Signed Les Woytek (Contractor)
Date 5-25-86

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434