

WELL DRILLERS REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 6194

PRINT OR TYPE ONLY

1. OWNER James & Deborah Filkins ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 5050 Carnoustie 4885 Piedmont
SE 1/4 SW 1/4 Sec 21 T 19 N/S R 20 E Washoe County
21-092-01 Parcel No. Lot 3 Eastside Sub #2 Subdivision Name
 Issued by Water Resources

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown & Black clay		0	22	22
coarse sands & brown clay		22	41	19
cobbles & boulders		41	61	20
brown clay & sands multi colored	X	61	108	47
sandy brownish green clay - firm		108	120	12
T.D. 120				
There is a 19' blank on the bottom of the 22' perf.				

8. 10"-56" WELL CONSTRUCTION
 Diameter hole 8 1/2 inches Total depth 120 feet
 Casing record 6 5/8
 Weight per foot 12.92 Thickness .188
 Diameter 6 5/8 inches From +3' feet To 120 feet
 Surface seal: Yes No Type slurry
 Depth of seal 61 feet
 Gravel packed: Yes No
 Gravel packed from 61 feet to 120 feet
 Perforations:
 Type perforation factory
 Size perforation 3/32 X 3
 From 79 feet to 101 feet

Date started 2/11/86, 19_____
 Date completed 2/12/86, 19_____
 7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew with air to clean and develop.			

9. WATER LEVEL
 Static water level 6' feet below land surface
 Flow 10 G.P.M. P.S.I.
 Water temperature cool ° F. Quality good

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling and Well Service, Inc.
 Contractor
 Address 2255 Glendale Ave. Sparks, Nv 89431
 Contractor
 Nevada contractor's license number 15291
 Nevada contractor's drillers number 1132
 Nevada driller's license number 1132
 Actual Driller

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

Signed Roger M. Thrall Contractor
 Date _____