

WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 5649

1. OWNER Mike Evans ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 601 Queens Way _____
Sparks, Nv 89431 _____
 2. LOCATION NW $\frac{1}{4}$ NE $\frac{1}{4}$ Sec 33 T. 20 _____
N/S R. 20 E Washoe County _____
 PERMIT NO. 04280 replacement Parcel No. 028-061-13 Subdivision Name _____
 Issued by Water Resources

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other mud & air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	25	25
volcanic rock		25	45	20
volcanic rock & brown clay		45	82	37
white and yellow clay		82	180	98
gray sandstone and volcanic rock		180	220	40
gray rock		220	240	20
gray clay and sandstone		240	282	42
yellow & white rock gray sandstone		282	330	48
T. D. <u>330</u>				

8. WELL CONSTRUCTION
 Diameter hole 12-8 inches Total depth 320 feet
 Casing record 8 and 6
 Weight per foot 10.78 - 22.36 Thickness .156 - .250

Diameter	From	To
<u>8/ 5/8</u> inches	<u>+2</u> feet	<u>120</u> feet
<u>6 5/8</u> inches	<u>100</u> feet	<u>320</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type Slurry
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 120 feet
 Perforations:
 Type perforation factory
 Size perforation 3/32 X 3 - .250
 From 100 feet to 120 feet
 From 300 feet to 320 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 70 feet below land surface
 Flow 10 G.P.M. _____ P.S.I.
 Water temperature cool ° F. Quality _____

Date started 4/23/85, 19_____
 Date completed 4/26/85, 19_____
 7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>Blew with air to clean and develop</u>			

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling and Well Service, Inc.
 Contractor
 Address 2255 Glendale Ave. Sparks, Nv 89431
 Contractor
 Nevada contractor's license number 15291
 Nevada contractor's drillers number 1132
 Nevada driller's license number 1439
 Actual Driller
 Signed Roger M. Thrall Contractor
 Date 4/29/85

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours