WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 26189
Permit No.
Basin 6-87 Truckee Meadows

PRINT OR TYPE ONLY

NOTICE OF INTENT NO.

1. OWNER Harvey Fenton
MAILING ADDRESS
ADDRESS AT WELL LOCATION 17998 Toll Rd Reno Nev.

2. LOCATION NE ¼ NE ¼ Sec. 2 T. 17 N/S R. 20 E. Washoe County
PERMIT NO. Issued by Water Resources | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Clay + Rock		0	100	100
Fractured Rock	✓	100	142	42

Date started 6/27, 1985
Date completed 6/29, 1985

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blown	18-20	0	2 Hr.

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 10" inches Total depth 142 feet
Casing record 6 5/8
Weight per foot 16 Thickness 156

Diameter	From	To
6 5/8 inches	0 feet	142 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Cement
Depth of seal 50' feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 50 feet to 142 feet

Perforations:
Type perforation Factory
Size perforation 3/32 x 3
From 120 feet to 142 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 50' feet below land surface
Flow 0 G.P.M. 18-20 P.S.I.
Water temperature Cold ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Sierra Pump + Drilling
Contractor
Address Carson City
Contractor
Nevada contractor's license number 0122366
Nevada contractor's drillers number —
Nevada driller's license number 1001
Actual Driller
Signed Cirtus Bladsworth by Jim Stracener
Contractor
Date 10/25/85

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434