

**WELL DRILLERS REPORT**

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 2241

1. OWNER Jim Henry ADDRESS AT WELL LOCATION 20680 COOKE DR.  
 MAILING ADDRESS 20680 COOKE DR.

2. LOCATION  $\frac{1}{4}$  Sec. 7 T. 17 S. R. 20 E. WASHOE County  
 PERMIT NO. none 045-333-01 PLEASANT VALLEY ESTATES  
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY & ROCK		0	42	
BROWN CLAY		42	45	
SANDY CLAY		45	71	
LIGHT BROWN CLAY		71	72	
SANDY CLAY		72	90	
BLACK BROKEN ROCK	✓✓	90	104	
SAND CLAY		104	120	
BLACK BROKEN ROCK	✓✓	120	130	

8. WELL CONSTRUCTION  
 Diameter hole 8 inches Total depth 130 feet  
 Casing record \_\_\_\_\_  
 Weight per foot \_\_\_\_\_ Thickness 188  

Diameter	From	To
<u>8</u> inches	<u>-1</u> feet	<u>130</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type GRAUT  
 Depth of seal 60' feet  
 Gravel packed: Yes  No   
 Gravel packed from 60 feet to 130 feet  
 Perforations:  
 Type perforation MILL SLOT  
 Size perforation 1/8" X 3  
 From 90 feet to 130 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level APPROX 60 feet below land surface  
 Flow none G.P.M. none P.S.I.  
 Water temperature WARM Quality GOOD

Date started 4-14, 1986  
 Date completed 4-15, 1986

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name PAUL WILLIAMS & SONS Contractor  
 Address 22 So. PATTERSON Contractor  
 Nevada contractor's license number 14483  
 Nevada contractor's drillers number ~~7448~~ 957  
 Nevada driller's license number 1418  
 Signed Paul E. Williams Actual Driller  
 Date 4-16-86 Contractor

AIR BALLER TEST  
 G.P.M. APPROX 25 Draw down 130 feet 2 hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours