

WELL DRILLERS REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 6720

OWNER Scott Wroblewski ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 300 Rhodes Rd. 230 Laramie Dr.
Reno, NV 89511

2. LOCATION SW 1/4 NW 1/4 Sec. 8 T. 17 N/S R. 20 E Washoe County
 PERMIT NO. 50-132-06 Pleasant Valley
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Blue green rock with some black rock highly fractured-medium		0	32	32
hard blue green rock with black		32	80	48
very hard blue green rock with some fractures		80	138	58
some soft layers		138	141	3
blue green rock medium hard	X	141	161	20
There is a 4' blank at the bottom of the perforated pipe to aid in development				
T.D. 161				

8. 10"-50' WELL CONSTRUCTION

Diameter hole 8 inches Total depth 161 feet
 Casing record 6 5/8 X .156
 Weight per foot 10.78 Thickness .155

Diameter	From	To
<u>6 5/8</u> inches	<u>+3</u> feet	<u>161</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type grout
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 161 feet

Perforations:
 Type perforation factory
 Size perforation 3/32 X 3
 From 137 feet to 157 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Date started 12/13/85, 19____
 Date completed 12/18/85, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew well with air to clean and develop.			

9. WATER LEVEL

Static water level 100' feet below land surface
 Flow 25 G.P.M. P.S.I. _____
 Water temperature cold ° F. Quality good

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling and Well Service, Inc.
Contractor
 Address 2255 Glendale Ave. Sparks, NV 89431
Contractor
 Nevada contractor's license number 15291
 Nevada contractor's drillers number 1132
 Nevada driller's license number 1132 Actual Driller
 Signed Roger M. Thrall Contractor
 Date 12/13/85

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours