WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

OFFICE USE ONLY
Log No. 26209
Permit No.
Basin 6-89 Washoe V.

NOTICE OF INTENT NO.

1. OWNER: BILL TREMAIN
MAILING ADDRESS: 2855 Ravazza Road, Reno, NV 89511
ADDRESS AT WELL LOCATION: 4095 East Lake Blvd., Reno, NV

2. LOCATION: ~~NE~~ ¼ ~~NE~~ ¼ Sec. 32 T. 17N ~~E/W~~ N/S R. 20 E. Washoe County
PERMIT NO. SE SW (Issued by Water Resources) | 050-416-03 (Parcel No.) | Washoe Valley (Subdivision Name)

3. TYPE OF WORK: New Well ☒ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☒ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☒ Other ☐ air

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Top soil | | 0 | 2 | 2 |
| Brown sand | | 2 | 18 | 16 |
| Brown sandy clay | | 18 | 74 | 56 |
| Soft zone NO WATER | | 74 | 76 | 2 |
| Brown sandy clay | | | | |
| with some gravels | | 76 | 104 | 28 |
| Soft zone | x | 104 | 110 | 6 |
| Brown sandy clay | | 110 | 125 | 15 |

N 39.288965
W 119.761249 NAD27

Deepened under NDI 60491
9-27-07 RC 1-8-08

Date started 11-5-84, 19
Date completed 11-5-84, 19

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | | | |

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 10 x 6 inches Total depth 125 feet
Casing record 125
Weight per foot Thickness .156

| Diameter | From | To |
|---|---|---|
| 6 5/8 inches | 0 feet | 125 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 125 feet

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 2½ x 6 around
From 97 feet to 117 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 65 feet below land surface
Flow 13 G.P.M. P.S.I.
Water temperature cold °F. Quality clear

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370, Reno, NV 89510 (Contractor)
Nevada contractor's license number 14043
Nevada contractor's drillers number 908
Nevada driller's license number 923 (Actual Driller)
Signed Gary C. Hedman (Contractor)
Date November 8, 1984

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434