

CCB

WELL DRILLERS REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO.6055

1. OWNER Raymond Swarts ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 549 University Terrace 410 Sylvan Cr.
Reno, Nv 89503

2. LOCATION SW 1/4 Sec. 7 T 19 N/S R. 18 E Washoe County
 PERMIT NO. 38-046-27 Sunrise Creek
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
cobbles and clay		0	20	20
hard rock		20	22	2
clay and cobbles		22	30	8
green clay stove		30	79	49
truckee formation		79	121	42
black & grayish rock	H20			
hard	X	121	138	17
T.D. 138				

8. WELL CONSTRUCTION
 Diameter hole 10 inches Total depth 138 feet
 Casing record 6 5/8"
 Weight per foot 12.92 Thickness .188

Diameter	From	To
<u>6 5/8</u> inches	<u>+3</u> feet	<u>138</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type neat cement
 Depth of seal 92 feet
 Gravel packed: Yes No
 Gravel packed from 92 feet to 138 feet
 Perforations:
 Type perforation factory
 Size perforation 3/32 X 3
 From 118 feet to 138 feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level _____ feet below land surface
 Flow 12 G.P.M. _____ P.S.I.
 Water temperature cold ° F. Quality _____

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling and Well Service, Inc.
Contractor
 Address 2255 Glendale Ave. Sparks, Nv 89431
Contractor
 Nevada contractor's license number 15291
 Nevada contractor's drillers number 1132
 Nevada driller's license number 1132
Actual Driller
 Signed Roger M. Thrall
Contractor
 Date 5/1/86

Date started 4/30/86, 19____
 Date completed 4/30/86, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>Blew with air to clean and develop.</u>			

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours