

WELL DRILLERS REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 6804

1. OWNER TOM JENSEN CONST/FRED PINKERTON ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 890XXX Thelma Place _____
Reno, NV 89509 _____
630 Dog Valley Road _____
Verdi NV 89439 _____

2. LOCATION SW 1/4 SE 1/4 Sec 7 T. 19N N/S R. 18 E _____
Washoe County

PERMIT NO. _____ Issued by Water Resources _____ Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other Air

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|---|--------------|------|-----|------------|
| Top soil | | 0 | 1 | 1 |
| Gravels & small boulders cemented with brown clay | | 1 | 18 | 17 |
| Brown clay | | 18 | 52 | 34 |
| Hard gray rock | | 52 | 56 | 4 |
| Gray clay | | 56 | 95 | 39 |
| Soft zone (2-3GPM) | x | 95 | 97 | 2 |
| Soft gray rock with some clay streaks | | 97 | 137 | 40 |
| Gray clay | | 137 | 162 | 25 |
| Soft zone | | 162 | 163 | 1 |
| Gray rock | | 163 | 190 | 27 |
| Soft zone | | 190 | 193 | 3 |
| Gray & green rock | | 193 | 208 | 15 |
| Soft zone | | 208 | 210 | 2 |
| Gray & green rock | | 210 | 265 | 55 |
| Hard gray rock & green | | 265 | 284 | 19 |
| Soft zone | | 284 | 286 | 2 |
| Gray & green hard rock | | 286 | 314 | 28 |
| Small fracture (NO WATER) | | 314 | 315 | 1 |
| Gray & green rock with small fracture (NO H2O) | | 315 | 355 | 40 |
| Gray & green rock | | 355 | 395 | 40 |
| Hard rock gray & green | | 395 | 402 | 7 |
| Soft zone | x | 402 | 450 | 48 |

8. WELL CONSTRUCTION

Diameter hole 10 x 6 inches Total depth 450 feet
 Casing record 450
 Weight per foot _____ Thickness .156

| Diameter | From | To |
|---------------------|---------------|-----------------|
| <u>6 5/8</u> inches | <u>0</u> feet | <u>450</u> feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |

Surface seal: Yes No Type cement
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 450 feet

Perforations:
 Type perforation factory sawed perforations
 Size perforation 3/32 x 2 1/2 x 6 around
 From 404 feet to 444 feet
 From _____ feet to _____ feet

9. WATER LEVEL

Static water level 27 feet below land surface
 Flow 17 G.P.M. _____ P.S.I.
 Water temperature cold °F. Quality clear

Date started 10-10-85 19____
 Date completed 10-15-85 19____

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|----------|--------|-----------|------------------|
| | | | |
| | | | |
| | | | |

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Wayne Drilling of Nevada, Inc. Contractor
 Address P.O. Box 12370, Reno, NV 89510 Contractor
 Nevada contractor's license number 22549
 Nevada contractor's drillers number 908
 Nevada driller's license number 923 Actual Driller
 Signed [Signature] Contractor
 Date October 17, 1985