WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 26790
Permit No.
Basin G-91 Truckee Canyon Stg.

# WELL DRILLERS REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 3933

1. OWNER Kenish Trust
MAILING ADDRESS PO BOX 950 VERDI NV
ADDRESS AT WELL LOCATION 200 LAKEVIEW DRIVE VERDI NV

2. LOCATION NE ¼ NE ¼ Sec. 18 T. 19 N/S R. 18 E. Washoe County
PERMIT NO. 38-053-10 (Issued by Water Resources)
Parcel No. 16
Subdivision Name: Verdi Lake Estate

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Boulders and cobbles | | 0 | 34 | 34 ft |
| Hard mudstone (Brown) | | 34 | 38 | 4 ft |
| Sandy clay with fine gravel | | 38 | 46 | 8 ft |
| Brown Lignite | ✓ | 46 | 90 | 44 ft |
| Dark grey hard sandstone | | 90 | 105 | 15 ft |
| light grey clay | | 105 | 110 | 5 ft |
| light Green clay | | 110 | 117 | 7 ft |
| Hard Fractured Black and white Rock | | 117 | 128 | 11 ft |
| Medium hard green and white rock | ✓ | 128 | 135 | 7 ft |

Date started 9-24, 1985
Date completed 10-1, 1985

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | | | |

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 9 7/8 inches Total depth 135 feet
Casing record
Weight per foot ..... Thickness .156

| Diameter | From | To |
|---|---|---|
| 12¼ inches | 0 feet | 34 feet |
| 9 7/8 inches | 34 feet | 135 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☑ No ☐ Type Sand + cement
Depth of seal ..... feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 51 feet to 135 feet

Perforations:
Type perforation Saw slot
Size perforation
From 100 feet to 135 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level approx. 17 ft feet below land surface
Flow ..... G.P.M approx. 15 ~~P.S.I.~~
Water temperature ..... ° F. Quality unknown

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Paul Williams & Sons (Contractor)
Address 22 So. Patterson, Sparks Nev. (Contractor)
Nevada contractor's license number 14483
Nevada contractor's drillers number 957
Nevada driller's license number 1287
Signed Paul E. Williams Jr. (Actual Driller) (Contractor)
Date 10-2-85

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434