

WELL DRILLERS REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 6800

OWNER AMERICAN STORAGE CENTER ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 325 Plaza Dr. Mt. Limbo
Prescott, AZ 86301
 2. LOCATION E 1/2 X 1/4 Sec 29 T 21 N/S R. 19 E Washoe County
 PERMIT NO. 086-130-02 Stead Center
 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	2	2
Brown Sandy Clay		2	7	5
Soft brown sand		7	9	2
Brown sandy clay		9	47	38
Soft brown sand		47	49	2
Brown sandy clay		49	71	22
Soft zone		71	76	5
Green weather granite		76	111	35
Soft zone		111	113	2
Green weather granite		113	116	3
Soft zone		116	127	11
Green weather granite w/ clay stk's		127	132	5
Soft zone		132	133	1
Green weather granite w/ clay stk's		133	143	10
Soft zone		143	148	5
Weather granite		148	151	3
Hard green granite		151	163	12
Fracture		163	165	2
Hard green granite		165	185	20
Smaller fracture		185	186	10
Hard green granite		186	195	9
Smaller fracture		195	196	1
hard green granite		196	200	4

8. WELL CONSTRUCTION
 Diameter hole 1.0 x 6 inches Total depth 200 feet
 Casing record 200
 Weight per foot _____ Thickness 156

Diameter	From	To
<u>6 5/8</u> inches	<u>0</u> feet	<u>200</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type cement
 Depth of seal 51 feet
 Gravel packed: Yes No
 Gravel packed from 51 feet to 200 feet
 Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 2 1/2 x 6 around
 From 93 feet to 113 feet
 From 163 feet to 193 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Date started 1-14-86, 19_____
 Date completed 1-15-86, 19_____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL
 Static water level 50 feet below land surface
 Flow 15 G.P.M. P.S.I.
 Water temperature cold °F. Quality clear

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling of Nevada, Inc. Contractor
 Address P.O. Box 12370, Reno, NV 89510 Contractor
 Nevada contractor's license number 22549
 Nevada contractor's drillers number 908
 Nevada driller's license number 923 Actual Driller
 Signed [Signature] Contractor
 Date 1-17-86

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours