

**WELL DRILLERS REPORT**

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 5891

1. OWNER WILLIAM HARVEY ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 9479 WIGWAM 11715 CHESAPEAKE  
RENO, NV 89506 RENO, NV 89506  
 2. LOCATION NE 1/4 S66 1/4 Sec. 15 T. 31N. N/S R. 19 E. WASHOE County  
 PERMIT NO. \_\_\_\_\_ LEMMON VALLEY Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock  Other  AIR

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP SOIL		0	1	1
BROWN CLAY		1	17	16
SOFT BROWN SANDY CLAY		17	23	6
SOFT GREEN SAND		23	26	3
BROWN SANDY CLAY		26	88	62
SOFT ZONE FINE SAND		88	94	6
SOFT BROWN SANDY CLAY		94	120	26
GREEN GRANITE		120	126	6
SOFT DG w/ BROWN CLAY STREAMS	X	126	141	25
DG		141	149	8

8. WELL CONSTRUCTION  
 Diameter hole 10 1/2 inches Total depth 149 feet  
 Casing record 149  
 Weight per foot \_\_\_\_\_ Thickness 156  
 Diameter 6 7/8 inches From 0 feet To 149 feet  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
 Surface seal: Yes  No  Type Cement  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 149 feet  
 Perforations:  
 Type perforation factory sawed slot  
 Size perforation 3/32 x 2 1/2 x 6 around  
 From 122 feet to 144 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 5-21-85 19\_\_\_\_  
 Date completed 5-22-85 19\_\_\_\_

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL  
 Static water level 6.8 feet below land surface  
 Flow 15 G.P.M. P.S.I. \_\_\_\_\_  
 Water temperature 60.2 °F. Quality clear

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Wayne Drilling Co. Inc. Contractor  
 Address P.O. Box 12370, Reno, NV 89510 Contractor  
 Nevada contractor's license number 22549  
 Nevada contractor's drillers number 908  
 Nevada driller's license number 923 Actual Driller  
 Signed Jerry C. Hedman Contractor  
 Date May 28, 1985

BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours