

**WELL DRILLERS REPORT**

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 6043

1. OWNER Byron Wholey ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS P. O. Box 60412 11815 Heartpine  
Reno, Nv 89506 Lennon Valley

2. LOCATION NE SW 15 21 N/S R. 19 E Wahhoo County  
 PERMIT NO. 80-353-07 Subdivision Name \_\_\_\_\_

Issued by Water Resources Parcel No. \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other  Air

6. LITHOLOGIC LOG

| Material                                | Water Strata | From | To  | Thick-ness |
|---|--------------|------|-----|------------|
| <b>Hard pan</b>                         |              | 0    | 42  | 42         |
| <b>Brown Clay &amp; D.G.</b>            |              | 42   | 96  | 54         |
| <b>D.G. with hard layers of granite</b> |              | 96   | 115 | 19         |
| <b>Hard granite - smooth</b>            | <b>X</b>     | 115  | 129 | 14         |
| T.D. 129'                               |              |      |     |            |

8. 10" - 55' WELL CONSTRUCTION  
 Diameter hole 8 1/2 inches Total depth 129 feet  
 Casing record 6 5/8  
 Weight per foot 12.92 Thickness .188

| Diameter            | From              | To              |
|---------------------|-------------------|-----------------|
| <u>6 5/8</u> inches | <u>+ 16"</u> feet | <u>129</u> feet |
| _____ inches        | _____ feet        | _____ feet      |
| _____ inches        | _____ feet        | _____ feet      |
| _____ inches        | _____ feet        | _____ feet      |
| _____ inches        | _____ feet        | _____ feet      |
| _____ inches        | _____ feet        | _____ feet      |

Surface seal: Yes  No  Type grout  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 129 feet

Perforations:  
 Type perforation factory  
 Size perforation 3/32 X 3  
 From 109 feet to 129 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 90 feet below land surface  
 Flow 20+ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool ° F. Quality good

Date started 2/16/86, 19\_\_\_\_  
 Date completed 2/16/86, 19\_\_\_\_

7. WELL TEST DATA

| Pump RPM  | G.P.M. | Draw Down | After Hours Pump |
|---|--------|-----------|------------------|
| <b>Blew well with air to clean and develop.</b> |        |           |                  |
|   |        |           |                  |
|   |        |           |                  |

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Aqua Drilling and Well Service, INC.  
 Contractor  
 Address 2255 Glendale Ave Sparks, Nv 89531  
 Contractor  
 Nevada contractor's license number 15291  
 Nevada contractor's drillers number 1132  
 Nevada driller's license number 1132  
 Actual Driller  
 Signed Roger M. Thrall Contractor  
 Date 2/6/86

BAILER TEST

|              |                      |             |
|--------------|----------------------|-------------|
| G.P.M. _____ | Draw down _____ feet | _____ hours |
| G.P.M. _____ | Draw down _____ feet | _____ hours |
| G.P.M. _____ | Draw down _____ feet | _____ hours |