

OFFICE USE ONLY
 Log No. 26360
 Permit No. _____
 Basin 7-92B Lemmon V. East

WELL DRILLERS REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 5812

1. OWNER BRIC NELSON ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 10305 Sutters Mill Chesapeake
Reno, NV 89506 Reno, NV 89506

2. LOCATION NE $\frac{1}{4}$ SW $\frac{1}{4}$ Sec. 23 T. 21N N/S R. 19 E Washoe County
 PERMIT NO. _____ Lemmon Valley
 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	2	2
Brown clay		2	11	10
Brown sand		11	15	4
Brown sandy clay		15	23	8
Brown sand		23	26	3
Brown sandy clay		26	51	25
Brown sand		51	53	2
Brown clay		53	68	15
Fine brown sand		68	72	4
Brown clay		72	86	14
Soft zone/fine sand		86	72	6
Brown clay		72	86	14
Soft zone/fine sand		86	88	2
Brown clay		88	105	17
Brown coarse sands	X	105	115	10
Brown clay		115	118	3
Coarse sands	X	118	119	1
Brown clay		119	125	6

8. WELL CONSTRUCTION
 Diameter hole 10 x 6 inches Total depth 125 feet
 Casing record 125
 Weight per foot _____ Thickness .156

Diameter	From	To
<u>6 5/8</u> inches	<u>0</u> feet	<u>125</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type cement
 Depth of seal 53 feet
 Gravel packed: Yes No
 Gravel packed from 53 feet to 125 feet

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 2 1/2 x 6 around
 From 97 feet to 118 feet
 From _____ feet to _____ feet

Date started 4-22-85, 19____
 Date completed 4-22-85, 19____

9. WATER LEVEL
 Static water level 69 feet below land surface
 Flow 30 G.P.M. _____ P.S.I.
 Water temperature cold ° F. Quality clear

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling of Nevada, Inc.
 Contractor
 Address P.O. Box 12370, Reno, NV 89510
 Contractor
 Nevada contractor's license number 22549
 Nevada contractor's drillers number 908
 Nevada driller's license number 923
 Actual Driller

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

Signed Wayne C. Hedman
 Contractor
 Date April 24, 1985