

OFFICE USE ONLY
 Log No. 20367
 Permit No. 3
 Basin 92B

WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 4656

1. OWNER Roger Bengé ADDRESS AT WELL LOCATION 10575 Chestnut
 MAILING ADDRESS 10575 Chestnut 10575 Chestnut
Reno, Nv 89506 Lemmon Valley
 2. LOCATION N 5W 1/4 NE 1/4 Sec. 26 T 21 N 19 E Washoe County
 PERMIT NO. 80-284-07
 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
D.G. Lite brown clay		0	20	20
Lite brown clay with green rock		20	40	20
Lite brown clay with D.G. & multi colored sands		40	138	98
First water	110'			
T.D. 138				

Deepened by
 NOT # 64062
 39.658907° N
 119.817341° W
 NAV 27 (FA)

* See Deepening Log # 109996

8. WELL CONSTRUCTION
 Diameter hole 10 inches Total depth 138 feet
 Casing record 6 5/8 .156 & .250
 Weight per foot 10.78 Thickness .156 .250
 Diameter 6 5/8 inches From +2 feet To 138 feet
 Surface seal: Yes No Type grout
 Depth of seal 100' feet
 Gravel packed: Yes No
 Gravel packed from 100 feet to 138 feet
 Perforations:
 Type perforation factory
 Size perforation 3/32 X 3 .250 wall
 From 118 feet to 138 feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 50 feet below land surface
 Flow 15+ G.P.M. _____ P.S.I.
 Water temperature cool ° F. Quality good

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling and Well Service, Inc.
 Contractor
 Address 2255 Glendale Ave. Sparks Nv 89431
 Contractor
 Nevada contractor's license number 15291
 Nevada contractor's drillers number 1132
 Nevada driller's license number 1439
 Actual Driller
 Signed Roger M. Thrall
 Roger M. Thrall Contractor
 Date 11/20/84

Date started 11/16/84
 Date completed 11/19/84

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew with air to clean & develop			

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours