WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 26372
Permit No.
Basin 7-92(B)

399-5773

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 6193

1. OWNER Fred Anglesberger
MAILING ADDRESS 220-D Booth St., Reno 89503
P.O. Box 21272, Reno 89515

ADDRESS AT WELL LOCATION 7575 Charlene

2. LOCATION SW ¼ ¼ Sec. 33 T. 21 N/S R. 19 E Washoe County
PERMIT NO. | Issued by Water Resources | Parcel No. 086-421-03 | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐ Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
clay & d.g. brown		0	119	
d.g. with little clay		119	129	
hard fractured granite		129	136	
d.g. firm		136	146	
brown clay		146	148	
d.g. firm		148	178	
hard fractured granite		178	196	
in & out of rock & clay with large gravels		196	290	
first H2O is at 280	280			
there is a 6' pc. of 6" casing on bottom of 6" casing string				
5-9/16" liner is approx. 195' to 257				
T.D. 290				

Date started 1/28/86, 19
Date completed 1/30/86, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
blow well with air to clean and develop.			

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. 10" - 55' WELL CONSTRUCTION
Diameter hole 8" & 6" inches Total depth 257 feet
Casing record 6 5/8 & 5 9/16
Weight per foot 12.92 & 7. + Thickness .188 & .134

Diameter	From	To
6 5/8 inches	+1 feet	240 feet
5 9/16 inches	195 feet	257 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type grout
Depth of seal 50' - 3 yards feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 240 feet

Perforations:
Type perforation factory
Size perforation 3/32 X 3
From 226 feet to 234 feet
From 237 feet to 257 feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 60 feet below land surface
Flow 25+ G.P.M. P.S.I.
Water temperature cool ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling and Well Service, Inc. (Contractor)
Address 2255 Glendale Ave., Sparks, NV 89431 (Contractor)
Nevada contractor's license number 15291
Nevada contractor's drillers number 1132
Nevada driller's license number 1132 (Actual Driller)
Signed Roger M. Thrall (Contractor)
Roger M. Thrall
Date 1/30/86

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434