

**WELL DRILLERS REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 0877

PRINT OR TYPE ONLY

1. OWNER S. W. Brown ADDRESS AT WELL LOCATION 17430 NORTHRIDGE AVE  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION NE 1/4 E. NE 1/4 Sec 29 T. 2 N. S. R. 18' E WASHOE County Washoe  
 PERMIT NO. 2529 (Northridge) COLD SPRINGS MN 711  
 Issued by Water Resources Parcel No. 2 Map 399 Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND/SOME GRAVEL		0	3	3
HARD PAN		3	4	1
SANDY CLAY		4	21	17
GRAVELLY SAND		21	35	14
SANDY CLAY		35	52	17
SANDY GRAVEL	✓	52	65	13
SANDY CLAY		65	87	22
BROWN SILTY SAND	✓	87	105	29
GRAVELLY SAND		105	120	15
SILTY SAND		120	126	6

Pump installed  
110'

8. WELL CONSTRUCTION  
 Diameter hole 12 1/4" - 8 inches Total depth 126 feet  
 Casing record \_\_\_\_\_  
 Weight per foot \_\_\_\_\_ Thickness 1.88  

Diameter	From	To
<u>8</u> inches	<u>0</u> feet	<u>126</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type Concrete  
 Depth of seal 50' feet  
 Gravel packed: Yes  No   
 Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Perforations:  
 Type perforation FACTORY MILLED  
 Size perforation 3/32" x 3  
 From 82 feet to 126 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level \_\_\_\_\_ feet below land surface  
 Flow 30 + G.P.M. P.S.I. \_\_\_\_\_  
 Water temperature 62.0 ° F. Quality Good

Date started SEPT. 16, 1985  
 Date completed SEPT. 21, 1985

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Burdett W. Brown Contractor  
 Address 215 Gavi Place Sparks Nev Contractor  
 Nevada contractor's license number 0013675  
 Nevada contractor's drillers number 831  
 Nevada driller's license number 1451 Actual Driller  
 Signed Burdett W. Brown Contractor  
 Date Sept 22, 1985

BAILER TEST  
 G.P.M. 25 Draw down 10 feet 2 hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours