

WELL DRILLERS REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 6508

PRINT OR TYPE ONLY

1. OWNER W.D. Miller ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS Skow Allard Rd  
Folsom  
 2. LOCATION S  $\frac{1}{4}$  SW  $\frac{1}{4}$  Sec 9 T. 16 N  $\frac{7}{8}$  R. 30 E Churchill County  
 PERMIT NO. 0312 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock  Other   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	8	8
Sand & Gravel		8	105	97
Red Volcanics		105	135	30
Green Shales		135	160	25
Black Volcanics		160	205	45
Red Volcanics		205	225	20
Green & Grey Shales		225	277	52
Basalt - Black		277	288	11
Black & Brown Basalt		288	307	19
Multi Colored				
Basalt and Clay		307	330	23
Sand & Clay		330	395	65

8. WELL CONSTRUCTION  
 Diameter hole 6 inches Total depth 393 feet  
 Casing record 6 5/8 x 393  
 Weight per foot 10.78 Thickness 0.156  

Diameter	From	To
<u>10</u> inches	<u>0</u> feet	<u>6.5</u> feet
<u>6</u> inches	<u>6.5</u> feet	<u>393</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type Cement  
 Depth of seal 65 feet  
 Gravel packed: Yes  No   
 Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Perforations:  
 Type perforation Machise Slot  
 Size perforation 3/16 x 2 1/2  
 From 340 feet to 390 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 1-29 1986  
 Date completed 2-5 1986

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>Air Blown @</u>	<u>35</u>	<u>G.P.M.</u>	

BAILER TEST

G.P.M.	Draw down	feet	hours
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

9. WATER LEVEL  
 Static water level 285 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ ° F. Quality \_\_\_\_\_

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Welsco Drilling Contractor  
 Address Box 888 Contractor  
 Nevada contractor's license number 1152  
 Nevada contractor's drillers number 772  
 Nevada driller's license number 772 Actual Driller  
 Signed W.D. Miller Contractor  
 Date 2-17-86