

WELL DRILLERS REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO.

1. OWNER D. Bendickson ADDRESS AT WELL LOCATION 4808 Allen Rd
 MAILING ADDRESS 4808 Allen Rd

2. LOCATION NE 1/4 SE 1/4 Sec. 14 T 18 N/S R 28 E Churchill County
 PERMIT NO. _____

Issued by Water Resources _____ Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	9	9
Clay		9	17	8
Fine Sand		17	22	5
Clay		22	32	10
Black Clay		32	38	6
Black Sand		38	48	10
Black Clay		48	76	28
Black Sand		76	78	2
Black Gravel		78	85	7
Grey Gravel		85	95	10
Sand & Gravel		95		
Grey Clay		95	100	5
Sand & Gravel		100	128	28

8. WELL CONSTRUCTION
 Diameter hole 8 7/8 inches Total depth 128 feet
 Casing record 8 5/8 X 128
 Weight per foot 16.94 Thickness .188

Diameter	From	To
<u>1 3/4</u> inches	<u>0</u> feet	<u>50</u> feet
<u>8 5/8</u> inches	<u>50</u> feet	<u>128</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type Cement
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet
 Perforations:
 Type perforation Machine Slot
 Size perforation 1/8 X 2 1/2
 From 118 feet to 126 feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 9 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ ° F. Quality _____

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wesco / J.W. Biffle Contractor
 Address Box 888 Contractor
 Nevada contractor's license number 11752
 Nevada contractor's drillers number 772
 Nevada driller's license number 772 Actual Driller
 Signed WCBiffle Contractor
 Date April 30 - 85

Date started April 27, 1985
 Date completed April 28, 1985

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>Air Blown @</u>	<u>150</u>	<u>G.P.M.</u>	

BAILER TEST

G.P.M.	Draw down	feet	hours