WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 26470
Permit No.
Basin 8-103 Dayton V.

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 3196

1. OWNER LYON CO. JULIUS BUNKOWSKI
MAILING ADDRESS PO BOX 718
CARSON CITY NEV 89701

ADDRESS AT WELL LOCATION
HWY 50 E DAYTON NEV 89403

2. LOCATION NESE¼ NE SE¼ Sec. 14/11 T. 16 N/S R. 21 E LYON County
PERMIT NO. 47954 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well [X] Recondition [ ]
Deepen [ ] Other [ ]

4. PROPOSED USE
Domestic [ ] Irrigation [ ] Test [ ]
Municipal [X] Industrial [ ] Stock [ ]

5. TYPE WELL
Cable [X] Rotary [ ]
Other [ ]

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Clay		0	10	10
Sand		10	35	25
Sand Water	35	35	38	3
Sand		38	52	14
Sand Gravle		52	70	18
Sand Gravle Water	70	70	73	3
Sandy Clay		73	80	7
Sand Gravle		80	90	10
Gravle Water	90	90	100	10
Gravle Sand		100	120	20
Pea Gravle Water	120	120	136	16
Sand Gravle		136	150	14
Clay		150	152	2
Sand Gravle				
Water	152	152	190	38
Sand		190	196	6
Sand Gravle Water	196	196	206	10

Date started June 3, 1985
Date completed June 29, 1985

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
40 Hp	550	176	24

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION

Diameter hole 10 inches Total depth 206 feet
Casing record Blank to 162 Blank to 141
Weight per foot XXXXX Thickness .188

Diameter	From	To
16 inches	0 feet	52 feet
10 inches	52 feet	206 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes [X] No [ ] Type Grout
Depth of seal 50 feet
Gravel packed: Yes [ ] No [X]
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation 3/32 Machine
Size perforation 3/32
From 162 feet to 206 feet
From 146 feet to 120 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL

Static water level 23 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... ° F. Quality Good

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Ace Pump Sales Ser. (Contractor)
Address 5551 Hwy. 50 East No 5 (Contractor)
Nevada contractor's license number 15489
Nevada contractor's drillers number 203
Nevada driller's license number 561 (Actual Driller)
Signed James W Thompson (Contractor)
Date 7-30-85

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434