

WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 26484

1. OWNER Robert L. Crist ADDRESS AT WELL LOCATION 487 Sam Clemens St. Unit 1 Las Vegas
 MAILING ADDRESS P.O. Box 18120 Reno, Nev 89511
 2. LOCATION $\frac{1}{4}$ Sec 30 T. 17 N/S R. 22 E Storey County
 PERMIT NO. 0115-9 (county?) Parcel No. _____ Subdivision Name Mark Train Estate II
Issued by Water Resources

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Brown clay, rock</u>		<u>0</u>	<u>120</u>	<u>120</u>
<u>Yellow clay</u>		<u>120</u>	<u>132</u>	<u>12</u>
<u>Brown clay, rock</u>		<u>132</u>	<u>176</u>	<u>44</u>
<u>rock gravel clay</u>		<u>176</u>	<u>184</u>	<u>8</u>
<u>clean gravel well</u>		<u>184</u>	<u>202</u>	

8. 12"=50' WELL CONSTRUCTION
 Diameter hole 8.52 inches Total depth 202 feet
 Casing record 8.52
 Weight per foot 16.5 Thickness 185 W.

Diameter	From	To
<u>8</u> inches	<u>0</u> feet	<u>202</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type concrete
 Depth of seal 50' feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet
 Perforations:
 Type perforation Factory
 Size perforation 3/32 x B
 From 182 feet to 202 feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 164 feet below land surface
 Flow _____ G.P.M. 20 P.S.I.
 Water temperature cold °F. Quality _____

Date started July 2 1984
 Date completed July 10 1984

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Labrum Well Drilling Contractor
 Address P.O. Box 543 Dayton, Nev. Contractor
 Nevada contractor's license number 14020
 Nevada contractor's drillers number 717
 Nevada driller's license number 717 Actual Driller
 Signed Warren W. Labrum Contractor
 Date July 11, 1984

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
 G.P.M. 20 Draw down 18 feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours