

WELL DRILLERS REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 5212

1. OWNER Lee Parks ADDRESS AT WELL LOCATION 3020 Sidney Carson, City NV. 89511  
 MAILING ADDRESS 3030 Brenda Carson, City 89511

2. LOCATION SW 1/4 NE 1/4 Sec 32 T 17 R 20 E Washoe County  
 PERMIT NO. none 050-371-03 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock  Other

5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND		0	23	
SANDSTONE		23	24	
VOID		24	28	
SAND		28	55	
OG		55	80	
GRANITE	uv	80	245	

8. WELL CONSTRUCTION  
 Diameter hole 10 inches Total depth 245 feet  
 Casing record 6" DIA  
 Weight per foot \_\_\_\_\_ Thickness 1.56  

Diameter	From	To
<u>6</u> inches	<u>-1</u> feet	<u>245</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type GRAUT  
 Depth of seal 60 feet  
 Gravel packed: Yes  No   
 Gravel packed from 60 feet to 245 feet

Perforations:  
 Type perforation MILL SLOT  
 Size perforation 1/8 X 3  
 From 185 feet to 205 feet  
 From 225 feet to 245 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 70 feet below land surface  
 Flow none G.P.M. none P.S.I.  
 Water temperature COOL ° F. Quality GOOD

Date started 3-27, 1986  
 Date completed 4-1, 1986

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name PAUL WILLIAMS Contractor  
 Address 22 So. PATTERSON Contractor  
 Nevada contractor's license number 14483  
 Nevada contractor's drillers number 957  
 Nevada driller's license number 1418 Actual Driller  
 Signed Paul E. Williams Contractor  
 Date 4-16-86

ALB TEST  
 G.P.M. approx 10 Draw down 220 feet 2 hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours