WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 26525
Permit No.
Basin 8-105 Carson V

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 6138

1. OWNER C. J. Royer
MAILING ADDRESS 1625 Main St. Minden Nevada 89423
ADDRESS AT WELL LOCATION 1004 Lakeview Dr. Gardnerville, NV 894

2. LOCATION SW ¼ SE ¼ Sec. 10 T. 12 N/S R. 19 E Douglas County
PERMIT NO. (Issued by Water Resources) Parcel No. Sierra Rancho Estates (Subdivision Name)

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden w/ Boulders		0'	6'	6'
Sand Stone w/ boulders		6'	70'	63'
Fractured Granite w/ Fine Grains	✓	70'	76'	6'
Broken Granite w/ Fine Grains		76'	94'	18'
Broken Granite w/ Fine Granite Sand	✓	94	107'	4'

Date started April-9, 1986
Date completed April-12, 1986

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Cleaned well without water, well making 35 G.P.M. +			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12 3/4 inches Total depth 107' feet
Casing record 8 5/8 O.D.
Weight per foot 16.88 Thickness .188

Diameter	From	To
8 5/8 inches	+2 feet	107' feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 58' to Surface feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 107' feet to 58' feet

Perforations:
Type perforation Mill Slot
Size perforation 3/32 X 3 1/2
From 85 feet to 102' feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 40' feet below land surface
Flow 25+ G.P.M. P.S.I.
Water temperature Cool °F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A+H Pump Co. (Contractor)
Address P.O. Box 3432 Carson City Nv. (Contractor)
Nevada contractor's license number 23295
Nevada contractor's drillers number
Nevada driller's license number 1472
Signed Quinton R. Butts (Actual Driller)
Date April 14, 1986 (Contractor)

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434