

WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 66614

1. OWNER MIKE Jarrett ADDRESS AT WELL LOCATION 1584 Marty Way
 MAILING ADDRESS Minden, Nv. Gardnerville, Nv.

2. LOCATION 1/4 Sec. 34 T. 12 N/S R. 20 E. Douglas County
 PERMIT NO. _____ Parcel No. _____ Subdivision Name Toler Lane

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
clay		0	7	
clay & gravel		7	57	
clay, sand, gravel	X	57	80	
clay		80	103	
Gravel, sand with clay streaks	XX	103	140	

8. WELL CONSTRUCTION
 Diameter hole 8 inches Total depth 140 feet
 Casing record +1-140
 Weight per foot _____ Thickness 188

Diameter	From	To
<u>12</u> inches	<u>0</u> feet	<u>51</u> feet
<u>8</u> inches	<u>51</u> feet	<u>140</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type grout
 Depth of seal 57 feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet
 Perforations:
 Type perforation factory
 Size perforation 3x3/32
 From 117 feet to 137 feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 45 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature cold ° F. Quality good

Date started 8-26-85
 Date completed 9-4-85

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Kawchack Drilling inc.
 Address Box 536 Gardnerville, Nv.
 Nevada contractor's license number 021268
 Nevada contractor's drillers number 1380
 Nevada driller's license number 1443
 Signed Andy Kawchack
 Date 9-4-85

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
 G.P.M. 17 Draw down 3 feet 15 hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours