

OFFICE USE ONLY  
Log No. 26583  
Permit No. 48321  
Basin 105-CARSON V.

**WELL DRILLERS REPORT**

PRINT OR TYPE ONLY  
Please complete this form in its entirety  
United Venture Capital, Inc.

NOTICE OF INTENT NO. 5535

1. OWNER Wally's Hot Springs ADDRESS AT WELL LOCATION North of Wally's  
MAILING ADDRESS P.O. Box 26 Hot Springs 1/2 mile on a gravel pit on the  
Genoa, Nv 89411 left side of highway.

2. LOCATION SW 1/4 SE 1/4 Sec. 15 T. 13 N/S R. 19 E Douglas County  
PERMIT NO. 48321-(26109) 17-212-01

Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
New Well  Recondition   
Deepen  Other

4. Commercial PROPOSED USE  
Domestic  Irrigation  Test   
Municipal  Industrial  Stock

5. TYPE WELL  
Cable  Rotary   
Other  Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Decomposed granite sand & gravel		0	90	90
Sand and gravel & clay		90	95	5
Sand & gravel		95	135	40
sand & gravel with clay		135	150	15
sand and gravel		150	190	40
sand & gravel & clay		190	200	10
sand & gravel		200	280	80
granite (bedrock)		280	282	2
T.D. <u>282</u>				
Bottom of casing has a cement plug				

8. WELL CONSTRUCTION  
Diameter hole 14 inches Total depth 282 feet  
Casing record 8" blank for 100'-perf & screen to 282  
Weight per foot 13.16 Thickness .156

Diameter	From	To
<u>8 5/8</u> inches	<u>+1'</u>	<u>282</u> feet
.....inches	.....feet	.....feet

Surface seal: Yes  No  Type slurry  
Depth of seal 50 feet  
Gravel packed: Yes  No   
Gravel packed from 50 feet to 282 feet

Perforations:  
Type perforation Factory - screen & perf  
Size perforation screen- single & double perf  
From 100 feet to 280 feet  
From .....feet to .....feet  
From .....feet to .....feet  
From .....feet to .....feet  
From .....feet to .....feet

Date started 1/25/85, 19.....  
Date completed 2/4/85, 19.....

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>Develop with air to clean &amp; develop.</u>			

BAILER TEST

G.P.M.	Draw down	feet	hours

9. WATER LEVEL  
Static water level 14' feet below land surface  
Flow 300+ G.P.M. P.S.I.  
Water temperature 78 ° F. Quality .....

10. DRILLERS CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Aqua Drilling and Well Service, Inc. Contractor  
Address 2255 Glendale Ave. Sparks, Nv 89431 Contractor  
Nevada contractor's license number 15291  
Nevada contractor's drillers number 1132  
Nevada driller's license number 1037 Actual Driller  
Signed Roger M. Thrall Contractor  
Date 2/11/85