

OFFICE USE ONLY
 Log No. 26591
 Permit No. 47608
 Basin 8-105 Carson V.

WELL DRILLERS REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 5567

PRINT OR TYPE ONLY

1. OWNER BENTLEY NEVADA CORPORATION ADDRESS AT WELL LOCATION BENTLEY SCIENCE PARK 2 MILES EAST MINDEN
 MAILING ADDRESS 1617 WATER STREET
MINDEN, NEVADA 89423

2. LOCATION SE $\frac{1}{4}$ NW $\frac{1}{4}$ Sec. 27 T. 13 N S R. 20 E DOUGLAS County
 PERMIT NO. 47608 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other Reverse

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
clay & topsoil		0	50	50
gravel w/clay mixed & layered		50	115	65
clay		115	128	13
gravel		128	145	17
clay		145	170	25
clay w/gravel mixed & layered		170	205	35
gravel	X	205	215	10
clay w/gravel layers	X	215	325	110
gravel w/some clay	X	325	345	20
clay		345	365	20
gravel	XX	365	378	13
clay		378	391	13
gravel	XXX	391	400	9
large gravel	XXX	400	410	10
gravel	XXX	410	415	5
clay		415	450	35
gravel w/some clay	XX	450	465	15
clay		465	475	10
clay & gravel layers	X	475	502	27

8. WELL CONSTRUCTION
 Diameter hole 8 inches Total depth 502 feet
 Casing record not cased
 Weight per foot _____ Thickness _____
 Diameter From To
 _____ inches _____ feet _____ feet
 Surface seal: Yes No Type _____
 Depth of seal _____ feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet
abandoned with cement grout seal
 Perforations:
 Type perforation _____
 Size perforation _____
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Electric Well Log by Geo-Hydro Data

Date started MARCH 19 19 85
 Date completed MARCH 21 19 85

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours

9. WATER LEVEL
 Static water level 25 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature cold ° F. Quality good

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name CHARLES SARGENT IRRIGATION, INC. Contractor
 Address P. O. BOX 2480 RENO, NV 89505 Contractor
 Nevada contractor's license number 21246
 Nevada contractor's drillers number 1391 LARRY WHITESEL
 Nevada driller's license number 1388 GENE MAPEL Actual Driller
 Signed Gene Mapel Contractor
 Date MARCH 25, 1985