WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 26611
Permit No.
Basin 8-105 Carson V.

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 6140

1. OWNER Larry Faught
MAILING ADDRESS 2336 Longview Dr
Bishop, Calif 93514

ADDRESS AT WELL LOCATION
2851 Tamara Court
APN# 21-290-26

2. LOCATION SE ¼ NW ¼ Sec. 11 T. 14 N/S R. 20 E. Douglas County
PERMIT NO. ____ (Issued by Water Resources) 11 (Parcel No.) Dangberg Estates (Subdivision Name)

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden w/sand		0	6	6
Fine grained tan sand	11	6	11	5
Fine to Medium sand with small pebbles	✓	11	38	27
Multi Colored sand fine to medium grain, carrying H_2O	✓	38	76	38
Black fine grained sand & silt	✓	76	92	16
Compact black clay w/fine grained sand		92	105	13
Medium to Coarse sand, multi colored black to white, carrying large quantity of water	✓	105	141	36
T.D. 141 ft				

Date started 3-31, 1986
Date completed 4-3-, 1986

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Flushed well for 3 Hours with clean water to remove bentonite drill mud.			
Well flowing, but shut in			

BAILER TEST
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION
Diameter hole 12 3/4 inches Total depth 141 feet
Casing record 8 5/8"
Weight per foot 15.56 #/ft Thickness .156

Diameter	From	To
8 5/8 inches	+2 feet	141 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete Redi Mix
Depth of seal 64' feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 64 feet to 141 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32" x 3 1/2"
From 116 feet to 136 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

9. WATER LEVEL
Static water level Flowing - Shut in feet below land surface
Flow 20 G.P.M. 4 P.S.I.
Water temperature Cool ° F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H Pump Co. (Contractor)
Address P.O. Box 3432 Carson City, NV (Contractor)
Nevada contractor's license number 23295
Nevada contractor's drillers number
Nevada driller's license number 1450 (Actual Driller)
Signed [signature] (Contractor)
Date April 4, 1986

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434