

WELL DRILLERS REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 6130

1. OWNER BARBARA ANDREOTTI ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 2639 Vicky Lane 2639 Vicky Lane  
Minden, Nevada Johnson Lane  
 2. LOCATION S2W 1/4 SE 1/4 Sec 33 T 14 N/S R. 20 E Douglas County  
 PERMIT NO. \_\_\_\_\_ 106 ACRES  
 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other  REPLACEMENT  
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock  Other   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Small Grained Sand from surface with small quantity of water from 137' to 103'</u>	<u>87</u>	<u>0</u>	<u>103</u>	<u>103</u>
<u>Tight, compact clay</u>		<u>103</u>	<u>111</u>	<u>8</u>
<u>Coarse to fine sand with small gravel carrying water</u>	<u>111</u>	<u>111</u>	<u>120</u>	<u>9</u>
<u>Total depth</u>				<u>120</u>

8. WELL CONSTRUCTION  
 Diameter hole 10 3/4 inches Total depth 120 feet  
 Casing record 6 3/8"  
 Weight per foot 11.7 Thickness 1.156  

Diameter	From	To
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type concrete  
 Depth of seal 52 feet  
 Gravel packed: Yes  No   
 Gravel packed from 62 feet to 120 feet  
 Perforations:  
 Type perforation FACTORY  
 Size perforation 3/8" X 3/16"  
 From 95 feet to 115 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started Dec 21 1985  
 Date completed Dec 20 1985

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>Blow well with 750 CFM at 200 psi for 1 1/2 hrs to clear debris</u>	<u>25 GPM from 90'</u>		

BAILER TEST

G.P.M.	Draw down	feet	hours
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

9. WATER LEVEL  
 Static water level 15 feet below land surface  
 Flow 25 G.P.M. P.S.I.  
 Water temperature cool ° F. Quality GOOD

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name A & H pumps Contractor  
 Address 511 Country Village Dr Carson City, NV Contractor  
 Nevada contractor's license number 23295  
 Nevada contractor's drillers number \_\_\_\_\_  
 Nevada driller's license number 1450  
 Signed Arthur G. Kelly Actual Driller  
 Date Dec 22, 1985 Contractor