

*DDAC*

**WELL DRILLERS REPORT**

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. \_\_\_\_\_

1. OWNER Eddy S Kawchack ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 1578 Chiguita Rt 3 Same as mailing address  
Minden, Nev. 89423

2. LOCATION SE 1/4 SE 1/4 Sec. 34 T. 14 N/S R. 20 E. Douglas County  
 PERMIT NO. 21-223-09 El Rancho Estates  
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

| Material               | Water Strata | From | To  | Thick-ness |
|------------------------|--------------|------|-----|------------|
| Sand & Clay top soil   |              | 0    | 2   |            |
| Sand, clay brush roots |              | 2    | 6   |            |
| Sand & Clay            |              | 6    | 31  |            |
| Sand, Clay & boulders  |              | 31   | 40  |            |
| Sand & clay            |              | 40   | 49  |            |
| Sand, clay boulders    |              | 49   | 53  |            |
| Sand & clay            |              | 53   | 82  |            |
| Clay                   |              | 82   | 101 |            |
| Sand & clay            |              | 101  | 151 |            |
| course sand & clay     | xx           | 151  | 163 |            |
| sand & clay            |              | 163  | 179 |            |
| Sand gravel & clay     | xx           | 179  | 190 |            |
| Clay                   |              | 190  | 195 |            |

8. WELL CONSTRUCTION  
 Diameter hole 6 inches Total depth 195 feet  
 Casing record \_\_\_\_\_  
 Weight per foot \_\_\_\_\_ Thickness 188  

| Diameter        | From          | To              |
|-----------------|---------------|-----------------|
| <u>6</u> inches | <u>0</u> feet | <u>195</u> feet |
| _____ inches    | _____ feet    | _____ feet      |
| _____ inches    | _____ feet    | _____ feet      |
| _____ inches    | _____ feet    | _____ feet      |
| _____ inches    | _____ feet    | _____ feet      |
| _____ inches    | _____ feet    | _____ feet      |
| _____ inches    | _____ feet    | _____ feet      |

 Surface seal: Yes  No  Type cement  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet

Perforations:  
 Type perforation Factory  
 Size perforation 3x1/16  
 From 170 feet to 190 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 126 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold ° F. Quality good

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Kawchack Drilling Inc. Contractor  
 Address 1578 Chiguita, Minden, Nev. 89423 Contractor  
 Nevada contractor's license number 021268  
 Nevada contractor's drillers number 1380  
 Nevada driller's license number 1380  
 Signed Eddy S Kawchack Actual Driller Contractor  
 Date 8/15/85

Date started 7/20, 1985  
 Date completed 8/3, 1985

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|----------|--------|-----------|------------------|
|          |        |           |                  |
|          |        |           |                  |
|          |        |           |                  |
|          |        |           |                  |

BAILER TEST  
 G.P.M. +20 Draw down 7 feet 2 1/2 hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours