

WELL DRILLERS REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 4844

PRINT OR TYPE ONLY

1. OWNER BANDILIO LOPAZ ADDRESS AT WELL LOCATION #15 FARMWAY
MAILING ADDRESS P.O. BOX 115
VERMONT, NV. 89447
2. LOCATION N.E. 1/4 SE 1/4 Sec 4 T. 13 S. R. 26 E Lyon County
PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
New Well Recondition
Deepen Other
4. PROPOSED USE
Domestic Irrigation Test
Municipal Industrial Stock
5. TYPE WELL
Cable Rotary
Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>BROWN CLAY</u>		<u>0</u>	<u>10</u>	<u>10</u>
<u>COURSE SAND</u>		<u>10</u>	<u>13</u>	<u>3</u>
<u>BROWN CLAY</u>		<u>13</u>	<u>17</u>	<u>4</u>
<u>COURSE SAND</u>		<u>17</u>	<u>20</u>	<u>3</u>
<u>CLAY + COURSE SAND</u>		<u>20</u>	<u>35</u>	<u>15</u>
<u>COURSE SAND + GRAVEL</u>		<u>35</u>	<u>50</u>	<u>15</u>
<u>CLAY + COURSE SAND + GRAVEL</u>		<u>50</u>	<u>75</u>	<u>25</u>
<u>COURSE SAND + GRAVEL</u>	<u>X</u>	<u>75</u>	<u>100</u>	<u>25</u>

8. WELL CONSTRUCTION
Diameter hole 10 7/8 inches Total depth 100' 1" feet
Casing record _____
Weight per foot _____ Thickness 156
Diameter 6 7/8 inches From 0 feet To 101 feet
_____ inches _____ feet _____ feet
Surface seal: Yes No Type GROUT
Depth of seal 50 feet
Gravel packed: Yes No
Gravel packed from 50' feet to 100' feet
Perforations:
Type perforation SAWED
Size perforation 3/32" X 3" X 6 Rows
From 78' feet to 100' feet
From _____ feet to _____ feet

9. WATER LEVEL
Static water level 19' 6" feet below land surface
Flow _____ G.P.M. _____ P.S.I.
Water temperature COLD ° F. Quality GOOD

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name OGDEN BROS. DRILLING
162 N. BYBER LN. Contractor
Address VERMONT, NV. 89447 Contractor
Nevada contractor's license number 156616
Nevada contractor's drillers number 870 + 530
Nevada driller's license number 870 Actual Driller
Signed Billy Ogden Contractor
Date 8-26-85

Date started 8-15, 1985
Date completed 8-20, 1985

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 20 Draw down 5 feet 1/2 hour
G.P.M. _____ Draw down _____ feet _____ hours
G.P.M. _____ Draw down _____ feet _____ hours