WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 26686
Permit No.
Basin 108-MA[illegible] V.

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 4212

1. OWNER Belle K Thurston
ADDRESS AT WELL LOCATION Thurston Way
MAILING ADDRESS P.O. Box 57
Yerington Nev 89447

2. LOCATION NW ¼ SW ¼ Sec. 9 T. 13 N/S R. 26 E Lyon County
PERMIT NO. Issued by Water Resources | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown clay and fine sand		0	12	12
Coarse sand		12	15	3
Brown Clay and fine sand		15	18	3
coarse sand		18	20	2
Brown clay and fine sand		20	25	5
Coarse sand and clay		25	28	3
clay		28	30	2
Coarse sand and gravel		30	38	8
Coarse sand, gravel with clay Strata		38	50	12
Coarse sand and gravel		50	55	5
Coarse sand, gravel and clay		55	60	5
Coarse sand and gravel		60	70	10
Coarse sand, gravel with clay		70	80	10
Coarse sand and gravel	X	80	99'6"	19'6"

Date started Dec 24, 1984
Date completed Dec 27, 1984

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 22 Draw down 4 feet ½ hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 10 5/8 inches Total depth 100'6" feet
Casing record .156
Weight per foot Thickness .156

Diameter	From	To
6 5/8 inches	+ 1 feet	99'6" feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type cement grout
Depth of seal 50 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 50 feet to 99'6" feet

Perforations:
Type perforation Sawed
Size perforation 3/32 X 3" 6 rows
From 80' feet to 99'6" feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level feet below land surface
Flow G.P.M. P.S.I.
Water temperature cold ° F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ogden Bros Drilling
Contractor
Address 162 N. Bybee Lane
Contractor
Nevada contractor's license number 15646
Nevada contractor's drillers number 15646
Nevada driller's license number 634
Actual Driller
Signed Larry Ogden
Contractor
Date Jan. 5, 1985

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434