WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 26704
Permit No. 27059
Basin 117

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 0437

OWNER Leland Wallace
MAILING ADDRESS Dyer, Nevada 89010
ADDRESS AT WELL LOCATION

2. LOCATION SW ¼ NW ¼ Sec 9 T 4 N/S R 36 E Esmeralda County
PERMIT NO. 27059 Issued by Water Resources
Parcel No.
Subdivision Name

3. TYPE OF WORK: New Well ☒ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☐ Irrigation ☒ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☒ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand & gravel		0	45	45
Clay		45	50	5
Sand & gravel		50	135	85
Clay		135	140	5
Sand & gravel		140	168	28
Clay & monor gravels		168	233	65
Cem. grav./ stks of clay		233	260	27
Clay		260	276	16
Cemented gravel		276	315	39
Clay		315	340	25
Clay/ stks of gravel		340	432	92
Cemented gravel		432	468	36
Clay/stks of gravel		468	540	72
Clay		540	553	13
Gravel		553	560	7
Clay & gravel		560	585	25
Gravel		585	590	5
Clay		590	605	15

RECEIVED RECEIVED
JUN 25 1985 JUN 25 1985
Div. of Water Resources, Las Vegas, NV
Div. of Water Resources Branch Office - Las Vegas, NV

Date started May 13, 19 85
Date completed May 23, 19 85

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	920	100'	2
	1300	115	4
	1500	123	6
	1800	135	8

BAILER TEST
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION
Diameter hole 26 inches Total depth 605 feet
Casing record
Weight per foot ____ Thickness .250

Diameter	From	To
16 inches	+1 feet	594 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal from 4' to 50' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 605 feet

Perforations:
Type perforation Milled slots
Size perforation 1/8 x 2½ D.C. 16 rows, 6" cent
From 127 feet to 480 feet
From 513 feet to 573 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 66 feet below land surface
Flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name THOMPSON DRILLING CO., INC. (Contractor)
Address 4185 West Harmon, Las Vegas, Nvada 89103 (Contractor)
Nevada contractor's license number 4286A
Nevada contractor's drillers number 582
Nevada driller's license number 1440 (Fowler) & 1398 (Mowery)
Signed Roland K. Thompson (Actual Driller) (Contractor)
Date June 7, 1985

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) 0-627 CR434