WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA BR-2
DIVISION OF WATER RESOURCES

# WELL DRILLERS REPORT

**Please complete this form in its entirety**

PRINT OR TYPE ONLY

OFFICE USE ONLY
Log No. 26722
Permit No.
Basin 10-129 Buena Vista V.

NOTICE OF INTENT NO. 5117

1. OWNER Coeur Exploration
MAILING ADDRESS 223 Glendale Ave.
Sparks, NV 89431

ADDRESS AT WELL LOCATION

2. LOCATION SW ¼ NE ¼ Sec. 10 T 28 N/S R 34 E PERSHING County
PERMIT NO. W-157 48783 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☐ Recondition ☐
Deepen ☐ Other ☒

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☒
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Gravel | | 0 | 25 | |
| Limestone | | 25 | 65 | |
| Gravel | | 65 | 75 | |
| CLAY GRAVEL | | 75 | 100 | |
| BROKEN VOLCANIC | 20 | 100 | 135 | |
| ANDESITE | | | | |
| Andesite | 20 gpm | 135 | 155 | |
| Andesite | | 155 | 350 | |
| Broken | 50 gpm | 350 | 360 | |
| Andesite | | 360 | 590 | |
| Broken Andesite | 110gpm | 590 | 900 | |

Date started May 5, 19 85
Date completed May 9, 19 85

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | | | |
| Airlift | 110 | | |

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 5-1/2 inches Total depth 900 feet
Casing record
Weight per foot ..... Thickness 1/4"

| Diameter | From | To |
|---|---|---|
| 6" inches | 0 feet | 153' 5" feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 0 to 153' feet
Gravel packed: Yes ☐ No ☒
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation
Size perforation
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 59' feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature warm ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Lang Exploratory Drilling, a Division of Longyear Company (Contractor)
Address 185 W. 3300 South SLC, UT 84115 (Contractor)
Nevada contractor's license number 0021976
Nevada contractor's drillers number 0021976
Nevada driller's license number 1410 (Actual Driller)
Signed ..... (Contractor)
Date 6-4-85

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434