WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 26762
Permit No.
Basin 10-149 Stone Cabin V.

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 1670

1. OWNER BTA Oil Producers
MAILING ADDRESS 104 So. Pecos
Midland, Texas 79701

ADDRESS AT WELL LOCATION Stone Cabin Valley

2. LOCATION SE ¼ NE ¼ Sec. 25 T. 6 N/~~S~~ R. 47 E Nye County
PERMIT NO. Waiver No. OG42 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☒ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	3	3
Volcanic Gravel & Boulders		3	84	81
Clay		84	90	6
Volcanic Boulders		90	95	5
Clay & Gravel		95	100	5
Volcanic Boulders		100	145	45
Sand		145	150	5
Clay & Gravel		150	180	30
Boulders & Clay		180	340	160
Water Bearing Sand	X	340	341	1
Boulders & Clay		341	450	109
Sandy Clay		450	452	2
Boulders & Clay		452	454	2
Water Bearing Sand	X	454	456	2
Boulders & Clay		456	475	19
Sandy Clay		475	500	25

Plugged See Log #26762

Date started January 4, 1986
Date completed January 13, 1986

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

Air Test ~~BAILER TEST~~
G.P.M. 20 Draw down 159 feet 3 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 10 inches Total depth 500 feet
Casing record 6 In. 0 - 500
Weight per foot 10.78 Thickness .156

Diameter	From	To
6 inches	0 feet	500 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 500 feet

Perforations:
Type perforation Factory
Size perforation 1/8" x 3" 6 Rows
From 294 feet to 502 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 341 feet below land surface
Flow G.P.M. P.S.I.
Water temperature 70 °F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Christiansen Drilling, Inc. (Contractor)
Address 557 Ely Avenue, Ely, Nevada 89301 (Contractor)
Nevada contractor's license number 14790
Nevada contractor's drillers number 641
Nevada driller's license number 641 (Actual Driller)
Signed Jerald P. Christiansen (Contractor)
Date February 12, 1986

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434