

OFFICE USE ONLY
 Log No. 26764
 Permit No. _____
 Basin 10-153 Dumb

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER M. Van Vliet & Sons ADDRESS Escalon, Calif

2. LOCATION 19296 1/4 Sec 28 T. 20 N/S R. 53 E Eureka County
 PERMIT NO. 19296 / 23739 Deepening of log 6522

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
This Well was drilled in May 18 1965				
16" in Diameter				
The Casing was broken at 135 ft				
A 12" Liner was installed & Well				
Deepen from 220 to 268 ft				
Gravel		220	268	48

8. WELL CONSTRUCTION
 Diameter hole 12 inches Total depth 268 feet
 Casing record _____
 Weight per foot 44 lbs Thickness 1/2"

Diameter	From	To
<u>12</u> inches	<u>0</u> feet	<u>268</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type _____
 Depth of seal _____ feet
 Gravel packed: Yes No
 Gravel packed from 0 feet to 220 feet

Perforations:
 Type perforation Factory
 Size perforation 1 x 2"
 From 168 feet to 268 feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 130 Feet below land surface 130
 Flow _____ G.P.M.
 Water temperature Cold ° F. Quality Good

Date started May 1 1985
 Date completed May 16 1985

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>Replaced by log 116425</u>			

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Ron Naillon
 Address Box 32 Eureka, Nevada
 Nevada contractor's license number _____
 Nevada driller's license number 925
 Signed Ron Naillon
 Date May 16 1985

BAILER TEST

G.P.M.	Draw down	feet	hours