

WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. \_\_\_\_\_

1. OWNER DAN RUSSELL ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS P.O. Box 343 \_\_\_\_\_  
Church, Nev. 89316 \_\_\_\_\_  
 2. LOCATION S.W. 1/4 SE 1/4 Sec. 22 T. 19 N. R. 55 E. White Pine County \_\_\_\_\_  
 PERMIT NO. \_\_\_\_\_ Issued by Water Resources \_\_\_\_\_ Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other  Reverse

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Clay</u>		<u>0</u>	<u>9</u>	
<u>Var. Sand, Silt-Clay</u>		<u>9</u>	<u>16</u>	
<u>Sand &amp; Gravel</u>		<u>16</u>	<u>51</u>	
<u>Clay</u>		<u>51</u>	<u>65</u>	
<u>Sand &amp; Gravel</u>		<u>65</u>	<u>69</u>	
<u>Clay</u>		<u>69</u>	<u>80</u>	
<u>Sand &amp; Gravel</u>		<u>80</u>	<u>87</u>	
<u>Coarse Sand</u>		<u>87</u>	<u>90</u>	
<u>Clay</u>		<u>90</u>	<u>92</u>	
<u>Clay &amp; Gravel Strakes</u>		<u>92</u>	<u>101</u>	
<u>Clay</u>		<u>101</u>	<u>128</u>	
<u>White Sandstone</u>		<u>128</u>	<u>131</u>	
<u>White Clay</u>		<u>131</u>	<u>135</u>	
<u>Sand &amp; Gravel</u>		<u>135</u>	<u>152</u>	
<u>Clay</u>		<u>152</u>	<u>158</u>	
<u>Sand &amp; Gravel</u>		<u>158</u>	<u>166</u>	
<u>Clay</u>		<u>166</u>	<u>168</u>	
<u>Sand &amp; Gravel</u>		<u>168</u>	<u>173</u>	
<u>Sand, Gravel, Occ. Clay</u>		<u>173</u>	<u>188</u>	
<u>Sand &amp; Gravel</u>		<u>188</u>	<u>207</u>	
<u>Var. Sand, Gravel, Clay</u>		<u>207</u>	<u>235</u>	

8. WELL CONSTRUCTION  
 Diameter hole 28 inches Total depth 233 feet  
 Casing record \_\_\_\_\_  
 Weight per foot \_\_\_\_\_ Thickness 250  
 Diameter \_\_\_\_\_ From \_\_\_\_\_ To \_\_\_\_\_  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
 Surface seal: Yes  No  Type Concrete  
 Depth of seal 50 ft feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 ft feet to 233 feet  
 Perforations:  
 Type perforation Reverse-Flow  
 Size perforation \_\_\_\_\_  
 From 113 feet to 233 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level \_\_\_\_\_ feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ ° F. Quality \_\_\_\_\_

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Plaschke Irrigation Co.  
 Address P.O. Box 10, Church, Nev.  
 Nevada contractor's license number 11882  
 Nevada contractor's drillers number 706  
 Nevada driller's license number 635  
 Signed Walter Plush Actual Driller  
 Date 5-1-85  
 Contractor

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M.	Draw down	feet	hours