WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 26773
Permit No.
Basin 161

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 19[illegible]

OWNER Cliff Houpt P.O. Box 457
MAILING ADDRESS Indian Springs NV.

ADDRESS AT WELL LOCATION Winston Ln
Indian Springs. NV.

2. LOCATION ¼ ¼ Sec. 148A T. 16S N/S R. 56 E. Clark County
PERMIT NO. (Issued by Water Resources) | East 3/2 of (Parcel No.) | West 1/8 of South 1/2 of North 3/4 of tract 48A (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand + Gravel		0	12	12
Clay + Gravel		12	16	4
Sandy Clay + gravel		16	47	31
Sandy Clay	WB	47	50	3
Sand + gravel	WB	50	60	10
Sandy Clay + gravel	WB	60	90	30
Caliche		90	124	34
Sandy Clay	WB	124	150	26
Sand + gravel	WB	150	156	6
Clay + Gravel	WB	156	175	19
Sand + gravel	WB	175	190	15

RECEIVED
MAR 1 1 1985
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 3-3-4, 1985
Date completed 3-8, 1985

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	no test.		

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12¼ inches Total depth 190 feet
Casing record 191 Ft 8"
Weight per foot 14 lb. Thickness .156

Diameter	From	To
8 inches	-1 feet	190 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Concrete
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 190 feet to 50 feet

Perforations:
Type perforation torch
Size perforation 1/8 inch by 4 inch
From 149 feet to 150 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 44 feet below land surface
Flow G.P.M. P.S.I.
Water temperature Cool °F. Quality good.

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name S & H Drilling (Contractor)
Address 3312 Thom Blvd. LV NV 89130 (Contractor)
Nevada contractor's license number 0022059
Nevada contractor's drillers number
Nevada driller's license number 1426 (Actual Driller)
Signed Steven Hamm (Contractor)
Date 3-11-85

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434