WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 26785
Permit No.
Basin 162

WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

in Book

NOTICE OF INTENT NO. 22[illegible]

1. OWNER Bill Martindale
MAILING ADDRESS
ADDRESS AT WELL LOCATION Tecopa & Mopa Vista

2. LOCATION NE ¼ NE ¼ Sec. 16 T. 19 S N/S R. 53 E ~~Country~~ Nye County
PERMIT NO. Issued by Water Resources | Parcel No. | Subdivision Name Country place two.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand.		0	5	5
Sand & Gravel		5	26	21
Sandy Clay		26	52	26
Brown Clay		52	65	13
Gravel & Clay		65	111	46
Gray Clay		111	128	17
Sand & Clay		128	156	28
Calichie	WB	156	165	9
Brown Clay		165	180	15
Calichie	WB.	180	197	17
Brown Clay		197	200	3

RECEIVED
JAN 13 1986
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 11-25, 1985
Date completed 11-28, 1985

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12¼ inches Total depth 200 feet
Casing record 8⅝" 200 ft.
Weight per foot 14.11 Thickness .156

Diameter	From	To
8⅝ inches	-1 feet	200 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement.
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 200 feet

Perforations:
Type perforation Torch.
Size perforation ⅛ inch by 6 inch.
From 160 feet to 200 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 102 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature Cool °F. Quality good.

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Custom Drilling Inc. (Contractor)
Address 4425 Stacey Ave LV NV (Contractor)
Nevada contractor's license number 19219.
Nevada contractor's drillers number
Nevada driller's license number 1426 (Actual Driller)
Signed [signature] (Contractor)
Date 12-1-85

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434