


Log No. 26790
 Permit No. 162
 Basin 162



WELL DRILLERS REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 2053
 ADDRESS AT WELL LOCATION NORTH OF FIG. ST.
AND WEST OF AESSIE
PAHRUMP

PRINT OR TYPE ONLY

1. OWNER RANDALL BROWN
 MAILING ADDRESS 5000 GOWAN
LAS VEGAS, NEV.

2. LOCATION $\frac{1}{4}$ SE $\frac{1}{4}$ Sec. 30 T. 19 N/S R. 53 E NYE County
 PERMIT NO. --- LOT 2 BLK E TUMBLEWEED ESTATES
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock Other

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>TOP SOIL</u>		<u>0</u>	<u>2</u>	<u>2</u>
<u>HARD BROWN CLAY</u>		<u>2</u>	<u>6</u>	<u>4</u>
<u>BROWN CLAY</u>		<u>6</u>	<u>10</u>	<u>4</u>
<u>SOFT BROWN CALECHE</u>		<u>10</u>	<u>28</u>	<u>18</u>
<u>BROWN CLAY</u>		<u>28</u>	<u>61</u>	<u>33</u>
<u>SOFT WHITE CALECHE</u>		<u>61</u>	<u>72</u>	<u>11</u>
<u>BROWN CLAY</u>		<u>72</u>	<u>106</u>	<u>34</u>
<u>HARD BROWN CLAY</u>		<u>106</u>	<u>114</u>	<u>8</u>
<u>BROWN CLAY</u>		<u>114</u>	<u>140</u>	<u>26</u>

8. WELL CONSTRUCTION

Diameter hole 9 inches Total depth 140 feet
 Casing record 140' 8 5/8" O.D.
 Weight per foot..... Thickness .156
 Diameter From To
12 inches 0 feet 50 feet
9 inches 50 feet 140 feet
 Surface seal: Yes No Type CEMENT
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from..... feet to..... feet
 Perforations:
 Type perforation TORCH CUT
 Size perforation 1/4" x 10"
 From 70 feet to 140 feet
 From..... feet to..... feet
 From..... feet to..... feet
 From..... feet to..... feet
 From..... feet to..... feet

RECEIVED

MAY 23 1985

Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started 5-7 1985
 Date completed 5-10 1985

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. Draw down.....feethours
 G.P.M. Draw down.....feethours
 G.P.M. Draw down.....feethours

9. WATER LEVEL

Static water level 42 feet below land surface
 Flow..... G.P.M. P.S.I.
 Water temperature..... ° F. Quality.....

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name RON FLOYD PUMP & DRILLING
Contractor
 Address P.O. Box 157 PAHRUMP, NEV.
Contractor
 Nevada contractor's license number 7479-A
 Nevada contractor's drillers number 1424
 Nevada driller's license number 1427- STAN HARDON
Actual Driller
 Signed [Signature]
Contractor
 Date 5-10-85