WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 26813
Permit No.
Basin

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 1954

1. OWNER Wilbert Wharton
MAILING ADDRESS Star Rt. Pahrump NV 89041
ADDRESS AT WELL LOCATION Mesquite & Chico Ln.

2. LOCATION SW ¼ NE ¼ Sec. 4 T. 20S N/S R. 53 E Nye County
PERMIT NO. ____ Issued by Water Resources | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Clay		0	6	6
Caliche		6	15	9
Clay & gravel		15	21	6
Sandy Clay		21	28	7
Sandy Clay & gravel		28	32	4
Sandy Clay		32	50	18
Sandy Clay & gravel	WB	50	58	8
Caliche		58	65	7
Sand Clay & gravel	WB	65	125	60
Caliche		125	131	6
Sandy Clay & gravel	WB	131	160	29

RECEIVED
APR 18 1985
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 3-22, 19 85
Date completed 3-25, 19 85

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION
Diameter hole 12¼ inches Total depth 160 feet
Casing record 161 Ft 8 inch
Weight per foot 14.11 Thickness .156

Diameter	From	To
8 inches	-1 feet	160 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 160 feet to 50 feet

Perforations:
Type perforation torch
Size perforation ⅛ inch by 6 inch
From 120 feet to 160 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 35 feet below land surface
Flow ____ G.P.M. ____ P.S.I.
Water temperature Cool °F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name S & H Drilling (Contractor)
Address 3312 Thom Blvd. LV NV 89130 (Contractor)
Nevada contractor's license number 22059
Nevada contractor's drillers number
Nevada driller's license number 1426 (Actual Driller)
Signed Steve S Hamed (Contractor)
Date 4-2-85

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434