

OFFICE USE ONLY
 Log No. 26819
 Permit No. _____
 Basin _____
 NOTICE OF INTENT NO. 1675

WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

1. OWNER Dan Geoffry ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS _____

2. LOCATION NE 1/4 NE 1/4 Sec 6 T 20 S N/S R 53 E Uye County _____
 PERMIT NO. _____ Parcel No. lot 28 Block C Landmark Sub Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay		0	49	49
Clay	x	49	54	5
Grey Clay		54	98	44
Clay	x	98	105	7
Clay		105	137	32
Clay	x	137	140	3

8. WELL CONSTRUCTION
 Diameter hole 12 7/8 inches Total depth 140 feet
 Casing record 8 5/8 x 140
 Weight per foot 14.11 Thickness 156
 Diameter From To
8 5/8 inches 0 feet 140 feet
 _____ inches _____ feet _____ feet
 Surface seal: Yes No Type Cement
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 140 feet
 Perforations:
 Type perforation torch
 Size perforation 1/8 x 6" 3 Rows
 From 100 feet to 140 feet
 From _____ feet to _____ feet

RECEIVED
 NOV 26 1985
 Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started 4-5, 1985
 Date completed 4-5, 1985

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
 Static water level 35 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ ° F. Quality _____

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Custom Drilling Inc Contractor
 Address 4425 Stacey Ave Ln. Contractor
 Nevada contractor's license number 19219
 Nevada contractor's drillers number 1081
 Nevada driller's license number 1081
 Signed [Signature] Actual Driller
 Date 11-20-85