WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 26822
Permit No.
Basin

1. OWNER Dennis Shotly ADDRESS Irene St. 1679

2. LOCATION SW ¼ SW ¼ Sec. 6 T. 20 S N/S R. 53 E. Nye County
PERMIT NO.

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Hard Pan &		0		
Brown Clay			47	47
Gleche		47	55	8
White Clay		55	78	23
Gleche	x	78	81	4
Clay		81	97	16
Gleche	xx	97	107	10
Clay		107	137	30
Gleche	xxx	137	155	18
Clay		155	160	5

RECEIVED
NOV 26 1985
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 8-8, 1985
Date completed 8-8-, 1985

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12¼ inches Total depth 160 feet
Casing record 8 5/8 X 160
Weight per foot 14.11 Thickness .156

Diameter	From	To
8 5/8 inches	0 feet	160 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 50 feet to 160 feet

Perforations:
Type perforation Torch
Size perforation 1/8 X 6"
From 120 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 37 Feet below land surface
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Custom Drilling Inc
Address 4425 Stacey Ave
Nevada contractor's license number 19219
Nevada driller's license number 1081
Signed [illegible]
Date 10-10-85

USE ADDITIONAL SHEETS IF NECESSARY

O-627