



WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. _____

OWNER Walter Steel
 MAILING ADDRESS _____

ADDRESS AT WELL LOCATION _____

2. LOCATION SW 1/4 SW 1/4 Sec 9 T 80 N/S R 53 E Nye County
 PERMIT NO. 43 Unit D Blk 36 Calvegas Ranch
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	49	49
Clay		49	51	2
Clay		51	79	27
Clay	X	78	82	4
Clay		82	99	17
Clay	X	99	102	3
Clay		102	135	33
Clay	X	135	140	5
Clay		140	160	20

8. WELL CONSTRUCTION
 Diameter hole 12 1/4 inches Total depth 160 feet
 Casing record 8 3/8
 Weight per foot 14.56 Thickness 1 1/2
 Diameter 8 3/8 inches From -18" feet To 160 feet
 _____ inches _____ feet _____ feet
 Surface seal: Yes No Type Cement
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 160 feet
 Perforations:
 Type perforation Touch
 Size perforation 1 1/2 x 6 2 Rows
 From 120 feet to 160 feet
 From _____ feet to _____ feet

RECEIVED

JUL 29 1985

Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started 6-24 1985
 Date completed 6-24 1985

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
 Static water level 41 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ ° F. Quality _____

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Custom Drilling Inc
Contractor
 Address 4425 Stacey Ave L.V.N
Contractor
 Nevada contractor's license number 19219
 Nevada contractor's drillers number _____
 Nevada driller's license number 1081
 Signed L.B. Cooper Actual Driller
Contractor
 Date 6-30-85