WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 26864
Permit No.
Basin

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 2040

1. OWNER James Lee
MAILING ADDRESS Pahrump, Nevada 89041
ADDRESS AT WELL LOCATION

2. LOCATION NW ¼ SE ¼ Sec. 17 T. 20-S N/S R. 53 E Nye County
PERMIT NO. (Issued by Water Resources) | Parcel No. 414 | Cal-Vegas Acres (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface		0	4	4
White Clay		4	28	24
Brown Clay		28	58	30
Gray Clay	x	58	90	32
Brown Clay	x	90	130	40
Tough Brown Clay		130	144	14
Soft Brown Clay	x	144	168	24
Tough Clay		168	185	17
Brown Clay	x	185	200	15

RECEIVED
SEP 30 1985
Div. of Water Resources
Branch Office - Las Vegas, NV

8. WELL CONSTRUCTION
Diameter hole 8 inches Total depth 200 feet
Casing record 200 ft. of 8in casing
Weight per foot 15 lbs. Thickness .156

Diameter	From	To
8 inches	0 feet	200 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type concrete
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 200 feet

Perforations:
Type perforation Torch Cut
Size perforation ½ in width 8 in long
From 100 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 36 feet below land surface
Flow G.P.M. P.S.I.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Charless Nyberg (Contractor)
Address St. Rt. Box 36525 (Contractor)
Nevada contractor's license number 7484
Nevada contractor's drillers number
Nevada driller's license number 725 (Actual Driller)
Signed Charles Nyberg (Contractor)
Date September 20 1985

Date started July 23, 19 85
Date completed July 24, 19 85

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 20 gals. Draw down 4 feet ¼ hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434