WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 26885
Permit No.
Basin

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 2053

1. OWNER NORMA KEEFER
MAILING ADDRESS GEN. DEL. PAHRUMP NEV.
ADDRESS AT WELL LOCATION S.W. CORNER OF MONEY ST. AND MICHAEL ST.

2. LOCATION ¼ N.W. ¼ Sec. 2 T. 21S N/S R. 53 E. NYE County
PERMIT NO. — (Issued by Water Resources) Parcel No. LOT 4 Subdivision Name

3. TYPE OF WORK: New Well ☒ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☒ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☒ Rotary ☐ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	1	1
HARD PAN		1	3	2
BROWN CLAY		3	7	4
CALECHE		7	9	5
GREY CLAY		9	16	7
BROWN CLAY		16	25	9
CALECHE		25	36	11
GREY CLAY		36	44	8
BROWN CLAY		44	72	28
CALECHE		72	77	5
BROWN CLAY		77	85	2
HARD BROWN CLAY		85	96	11
BROWN CLAY		96	104	8
HARD BROWN CLAY		104	116	12
BROWN CLAY		116	140	24

RECEIVED
FEB 19 1985
Div. of Water Resources
Branch Office - Las Vegas, NV.

Date started 1-29, 1985
Date completed 2-2, 1985

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 9 inches Total depth 140 feet
Casing record 140' - 8 5/8" O.D. .156
Weight per foot ..... Thickness .156

Diameter	From	To
12 inches	0 feet	50 feet
9 inches	50 feet	140 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type CEMENT
Depth of seal 50 FT. feet
Gravel packed: Yes ☐ No ☒
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation TORCH CUT
Size perforation ¼" x 8"
From 70 feet to 140 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 36 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... ° F. Quality .....

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name RON FLOYD PUMP & DRILLING (Contractor)
Address P.O. BOX 157 PAHRUMP, NEV. (Contractor)
Nevada contractor's license number 7479-A
Nevada contractor's drillers number 1424
Nevada driller's license number 1424 STAN HARDIN (Actual Driller)
Signed [signature] (Contractor)
Date 2-3-85

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434